



# Certificate of Compliance

**Certificate:** 70150938

**Master Contract:** 270882

**Project:** 80004752

**Date Issued:** 2019-06-06

**Issued To:** UNI-TECH Automation Pvt. Ltd.  
Gat No. 837, 838, Palshi Road,  
Off Pune-Bangalore Highway,  
Shirwal, Khandala  
Satara, Maharashtra, MAH, 412801  
India

**Attention:** P. A. Sivanandam

*The products listed below are eligible to bear the CSA Mark shown*

**Issued by:** *Claudia Ibarra*  
Claudia Ibarra



## **PRODUCTS**

CLASS 5853-01 WIRES Coil-Lead

Coil lead wires, Type CL1503, with XLPE insulation, rated 150C, 600V, optional FT2, sizes 22 to 2 AWG.

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 127-18 Equipment and Lead Wires



## *Supplement to Certificate of Compliance*

**Certificate:** 70150938

**Master Contract:** 270882

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80004752	2019-06-06	Addition of optional flame classification FT2 to CL1503 rated 150C, 600V, optional FT1. Insulation: XLPE. Deletion of optional flame classification FT1. Update to CSA C22.2 No. 127-18.
70150938	2017-10-30	Original Certification of Coil lead wires, Type CL1503, rated 150C, 600V, FT1, with XLPE insulation, sizes 22 to 2 AWG. CSA Standard C22.2 No. 127-15.